

PASSAIC VALLEY WATER COMMISSION
CONTRACT #15-B-34
FILTER BAY EXHAUST FAN REPLACEMENT

ADDENDUM NO. 1

The drawings and specifications for the reference contract are hereby amended by this addendum. This addendum shall be attached to and become part of the Contract Documents. Acknowledge receipt of this addendum in the space provided on Page P-14 in the Contract Documents.

TIME EXTENSION FOR BIDDING

Addendum No. 1 postpones the date of Receipt of Sealed Bids to Tuesday, June 16, 2015 at 2:00pm local time at the PVWC offices at 1525 Main Avenue, Clifton, NJ.

PROJECT DRAWINGS

1. On sheet SK-1, note #5, replace the note with the following:

“Existing starters shall be re-used. The contractor is responsible for coordinating with the motor vendor to replace the overloads with the appropriate overloads sized for the new motor horsepower. A local NEMA 4X disconnect shall be located adjacent to the fan motor, mounted on the wall. Connect to existing conduit system at nearest fitting. Splice into existing circuit at nearest pull box and connect to motor controllers on the ground floor. Wire to motors using 12” length liquid tight flexible metallic conduit.”

++END OF ADDENDUM NO. 1++